



# **DOP-110CS**

High color • Wide screen • User-friendly
Delta Electronics, Inc.
No.18, Xinglong Rd., Taoyuan City
33068, Taiwan

## **Instruction Sheet**

#### (1) General precautions

Thank you for purchasing this product. This instruction sheet provides information about the DOP-100 series HMI. Before using this product, please read through this instruction sheet carefully to ensure the correct use of the product. Please keep this sheet handy for quick reference whenever needed. Before finishing reading this sheet, please follow the instructions below:

- Install the product in an indoor location, which is free of vapor, corrosive and inflammable gas and liquids.
- Please refer to the wiring diagram when connecting the wires.
- Ensure your HMI is correctly grounded. The grounding method must comply with the national electrical standard (please refer to NFPA 70: National Electrical Code, 2005 Ed.).
- Do not disassemble the HMI or change the wiring when power is on.
- Do not touch the power supply when power is on, or it may cause electric shock.
- When the HMI displays a low power notification and requires a battery change, please contact your local distributor or Delta Customer Service Center for the replacement. Do not change the batteries by yourself.
- This product can be used with other industrial automation equipment. Please read through this sheet carefully and install the product according to the instructions to avoid danger.
- Cleaning method: please use a dry cloth to clean the product.
- This product must be used at an altitude below 2,000 m.
- If the equipment is used in a manner not specified by the manufacturer, the protection provided by the equipment may be impaired.
- For repair and maintenance, please contact Delta Electronics, Inc. Address: No.18, Xinglong Rd., Taoyuan City, Taiwan. TEL: +886-3-3626301.

If you have any inquiry during operation, please contact our local distributors or Delta sales representatives. The content of this instruction sheet may be revised without prior notice. Please consult our distributors or download the latest version at Delta's website (<a href="http://www.delta.com.tw/ia">http://www.delta.com.tw/ia</a>).

## (2) Communication port pin assignment

## DOP-110CS COM1

COM Port	Pin	MODE1 RS-232
	1	-
	2	RXD
	3	TXD
a (1 5) a	4	-
	5	GND
6 6 9	6	-
	7	RTS
	8	CTS
	9	-


#### DOP-110CS COM2

		MODE1		MODE2		MODE3	
COM Port	Pin	COM2	COM3	COM2	СОМЗ	COM2	СОМЗ
		RS-232	RS-485	RS-485	RS-485	RS-232	RS-422
	1	-	-	D+	-	-	TXD+
	2	RXD	-	-	-	RXD	-
	3	TXD	-	-	-	TXD	-
5 1 2	4	-	D+	-	D+	-	RXD+
0 (0000)	5	GN	ID .	GI	ND .	GN	ĪD
(g 6) V	6	-	-	D-	-	-	TXD-
	7	RTS	-	-	-	RTS	-
	8	CTS	-	-	-	CTS	-
	9	-	D-	-	D-	-	RXD-

Note: mark "-" means connection is not required.


## (3) Description of each part

#### DOP-110CS (front view)



A Operation / display area


#### DOP-110CS (rear view)



Α	Power input terminal (24AWG wire min.)	В	COM2 / COM3
С	COM1	D	USB Host
Е	USB Slave		

#### (4) Mounting dimensions

#### DOP-110CS



Operation temperature: 0°C to 50°C (32°F to 122°F) Storage temperature: -20°C to 60°C (-4°F to 140°F)

#### (5) Installation and wiring


#### Precautions:

- Incorrect installation may result in malfunction.
- To ensure the HMI is well ventilated, make sure there is sufficient space between the HMI and the adjacent objects or walls.
- This product should be used on a case / platform which conforms to enclosure Type 4X standard (for indoor use only).
- The maximum panel thickness for mounting must be no greater than 5 mm.
- Copper conductor only.

#### Installation steps:

#### Step 1:


Put the waterproof gasket into the HMI and then insert the HMI into the panel cutout.



#### Step 3:


Tighten the screws with the torque less than 0.5 N-M / 0.7 N-M to avoid damage to the plastic case.

Torque for DOP-110CS: 6.17 lb-inch (0.7 N-M)




#### Step 2:

Place the fasteners into the slots and tighten the screws until reaching the panel cutouts.



Sten 4:

For heat dissipation, please keep a minimum clearance of 60 mm on the rear of the HMI.




#### Wiring:

Туре	Wire gauge (AWG)	Stripped length	Torque
Solid	24 – 12	7 – 8 mm	5 kg-cm (4.3 lb-in)
Stranded	24 – 12	7 – 8 mm	5 kg-cm (4.3 lb-in)



Unit: mm (inch)

Please refer to the following diagram when wiring the power connector. The temperature rating of the cable must be greater than 75°C (167°F).



	lware speci	
Mo	Danaltuna	DOP-110CS
Panel type  Resolution		10.1" TFT LCD (65535 colors)  1024 x 600 pixels
Discussion	Backlight	LED Back Light
Display	Display	(half-life under room temperature 25°C > 20,000 hours)*1  226 mm x 128.7 mm
	range Brightness	
	:PU	300 cd / m² (Typ.)  ARM Cortex-A8 (800 MHz)
	n ROM	256 Mbytes
	AM	256 Mbytes
	nscreen	4-wire resistive touchscreen > 1,000,000 operated
	ızzer	Multi-tone Frequency (2K - 4K Hz) / 80dB
	interface	N/A
U	ISB	1 USB Slave Ver. 2.0; 1 USB Host Ver. 2.0
	SD	N/A
2	COM1	RS-232 (supporting flow control)*2
Serial communication	COM2	RS-232 (supporting flow control) / RS485*2
port COM3		RS-422 / RS-485* <sup>2</sup>
Auxiliary f	function key	N/A
Calendar		Built-in
Cooling	g method	Natural cooling
Approvals		CE / UL (please use shielding network cable and magnetic ring with the filter of 300 ohm / 100 MHz)
Panel waterproof level		IP65 / NEMA4 / UL TYPE 4X (indoor use only)
Operation voltage*2		DC +24V (-15% to +15%) (please use an isolated power supply) Supplied by Class 2 or SELV circuit (isolated from MAINS by double insulation)
Leakage current		500 V <sub>AC</sub> for 1 minute (between DC24V terminal and FG terminal)
Power consumption*2		10.4 W (Max)*3
Backu	p battery	3V lithium battery CR2032 × 1
Backup	battery life	About 3 years or more at 25°C (subject to operation temperature and condition)
Operation	temperature	0°C to 50°C (32°F to 122°F)
Storage to	emperature	-20°C to +60°C (-4°F to 140°F)
Operating	environment	10% to 90% RH [0°C - 40°C], 10% to 55% RH [41°C - 50°C]; pollution degree: 2
Vibration resistance		Conforms to IEC61131-2: continuous vibration 5 Hz - 8.3 Hz with amplitude 3.5 mm; 8.3 Hz - 150 Hz with amplitude 1G
Shock resistance		Conforms to IEC60068-2-27: 11 ms, 15 G Peak, in X, Y, Z directions each for 6 times
	ension ) x (D) mm	272 x 200 x 61
Mounting	dimension (H) mm	261.3 x 189.3
	eight	Approx. 1330 g
maximum room tem	n drive current in perature of 25°	ight is defined as the maximum luminance being reduced by 50% when a supplied to the HMI. The life of LED backlight shown here is estimated PC with ambient humidity.
<ul><li>3. The HMI periphera supply is</li><li>4. Isolated p</li></ul>	power consum al devices. To el 1.5 to 2 times o power supply is	the isolated power circuit is 1500V peak for 1 minute. ption is the power consumed when the HMI is not connecting with other usure normal operation of the HMI, the recommended capacity of the post the specified power consumption.  recommended.  mming software of the DOP-100 series and the user manual, you can
download	them at <a href="http://">http://</a> series can be	www.delta.com.tw/ia.  used with other industrial automation equipment. Please read through the lift of the product according to the instructions to avoid danger.